

Red Oak Fire Rescue

Company Performance Standards

Rural Water Supply

OBJECTIVE:

Perform rural water supply drafting operation from portable tank using tanker apparatus and engine company to flow water for fire suppression. Perform drafting operation using 1 engine, 1 tanker, 1 portable tank to flow minimum of 300 gpm's. (a) May use nozzles to flow required gpm or supply another engine with same gpm requirement. (b) Recommended time of 5 minutes is timed from departure from staging area until all lines are properly supplied. (c) NFPA 6 may be a guideline for set up of operation.

INSTRUCTIONS:

1. Demonstrate the procedure for assembling and connecting equipment necessary for drafting from a static water supply.
2. Identify guidelines to follow when deploying a portable water tank.
3. Identify equipment necessary for the transfer of water between tanks.
4. Identify guidelines for loading and off-loading tanks on tanker units.
5. Perform drafting operation using a static source (portable tank) and required equipment to satisfy flow requirements of 300 gpm.

PREPERATION & EQUIPMENT

- Engine
- Tanker
- Portable Tank
- Hose and appliances

❖ **All personnel at a minimum will don helmets, boots, and gloves.**

Red Oak Fire Rescue
Company Performance Standards
Rural Water Supply

Activity	Pass	Fail
1. Demonstrates the procedure for assembling and connecting equipment necessary for drafting from static water source.		
2. Identifies guidelines to follow when deploying portable water tank.		
3. Identifies equipment necessary for transfer of water between tanks.		
4. Identifies the guidelines for loading and off-loading tanks on tanker unit.		
5. Performs drafting operation using a static source (portable tank) and required equipment to satisfy 300 gpm water flow.		

Date: _____ Shift: _____

Officer: _____ Driver: _____
 Firefighters _____

Total points possible: 5 Time to complete task: _____

Total points scored: _____

Performance rating of company on this standard: PASS _____ FAIL _____

First Attempt _____ Retest _____

Comments:

Officer Signature: _____ Date: _____

Evaluator Signature: _____ Date: _____